



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-069	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	May 10, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD water system is available via the existing 16-inch water main along Albemarle Road.

Access to the CMUD sewer system is available via the existing 10-inch gravity sewer mains located in the Northwest corner of parcel, starting at Interstate 485 and heading north.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.