



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-080	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	July 10, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 8-inch water main along Hawthorne Lane..

Access to the CMUD Sewer Service is available from the existing 10-inch gravity sewer main locate to the Southwest of property. This sewer main crosses the bottom Southwest corner of parcel under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.