



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-083	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	July 10, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 16-inch water main along Johnston Road, and the existing 8-inch water main along Marvin Road.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer main which runs through middle of parcel under review, along Clems Creek Lane.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.