

Charlotte Mecklenburg Utility Department 5100 Brookshire Boulevard Charlotte, NC 28062 Re-Zoning Petition Review

Petition #:	2014-089	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	August 19, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 24-inch water main along South Summit Avenue, the existing 12-inch water mains along Grandin Road and South Summit Avenue, and the existing 6-inch water main along West 4th Street..

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains located along West 4th Street, South Summit Avenue, and Grandin Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.