



**Charlotte Mecklenburg Utility Department**  
5100 Brookshire Boulevard  
Charlotte, NC 28062  
Re-Zoning Petition Review

<b>Petition #:</b>	2014-091	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	August 19, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 8-inch water main along Crescent Executive Drive and the existing 30-inch water main along West Arrowood Road.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains located along Crescent Executive Drive and Green Ridge Drive, and the existing 42-inch gravity sewer main running along Sugar Creek..

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.