



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

| | | | |
|---------------------------|--------------|-----------------------|--------------------------|
| Petition #: | 2014-092 | Review Number: | 1 |
| Petition Reviewer: | Matt Bedford | Date Reviewed: | August 19, 2014 |
| Phone Number: | 704-391-5163 | Email Address: | mbedford@charlottenc.gov |

Comments:

Access to the CMUD Water System is available via the existing 8-inch and 12-inch water mains along Tyvola Road and the existing 12-inch water main along Nations Ford Rd.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains located along Nations Ford Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.