



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-095	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	August 19, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 16-inch water mains along Salome Church Road and North Tryon Street.

Access to the CMUD Sewer Service is currently available from two existing 8-inch gravity sewer mains located at the North point of parcel 029-052-13, and the South side of intersection of North Tryon Street and Pavilion Boulevard.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.