



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-103	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	September 25, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 8-inch water main along Endhaven Lane.

Access to the CMUD Sewer Service will require the developer to connect to existing 8-inch gravity sewer mains along Misty Ridge Lane or Barrette Place. Possible connection points are 300 to 500 feet away from parcel. The developer will need to work with CMUD's IDS group to provide connection to the sewer system.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.