



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-111	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	September 25, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 12-inch water main along Albemarle Road.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains that run through parcel and along Albemarle Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.