



To: Tammie Keplinger, CMPC  
From: Ashley Botkin, Engineering Land Development  
Date: September 19, 2014  
Rezoning Petition #: 2014-111

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: <http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

**Comments for this rezoning:**

John Geer – no wetland

Tom Ferguson – Please DELETE existing Notes 7a and 7b under "PCCO TREATMENT". (PCCO applicability and compliance options will be determined upon site plan submittal for review and permitting. Regional storm water management facilities are routinely allowed when properly designed and the required easements are established.)

Please ADD the following note under "PCCO TREATMENT": *"The location, size, and type of storm water management systems depicted on the Rezoning Plan are subject to review and approval as part of the*

*full development plan submittal and are not implicitly approved with this rezoning. Adjustments may be necessary in order to accommodate actual storm water treatment requirements and natural site discharge points.”*

Tim Porter – Submit tree survey showing all trees in road right of way.