



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-116	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	October 22, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD water system is available from the existing 6-inch water main along Abbey Place.

Access to the CMUD Sewer System is available from the existing 8-inch gravity sewer main along Abbey Place.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.