



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2015-007	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	November 25, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 16-inch water mains along Rea Road and Williams Pond Lane.

Access to the CMUD Sewer Service is available from the existing 12-inch gravity sewer main along Rea Road and the existing 8-inch gravity sewer main crossing SE corner of parcel under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.