



**Charlotte Mecklenburg Utility Department**  
5100 Brookshire Boulevard  
Charlotte, NC 28062  
Re-Zoning Petition Review

<b>Petition #:</b>	2015-008	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	November 25, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 24-inch water main along Idlewild Rd, the existing 16-inch water main along Margaret Wallace Rd, and the existing 8-inch water mains along Wyalong Drive and Mintworth Avenue.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains along Idlewild Road, Margaret Wallace Road, Wyalong Drive, and Mintworth Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.