



**Charlotte Mecklenburg Utility Department**  
**5100 Brookshire Boulevard**  
**Charlotte, NC 28062**  
 Re-Zoning Petition Review

<b>Petition #:</b>	2015-013	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	December 22, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 48-inch and 8-inch water mains along Kenilworth Avenue.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer main along Kenilworth Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.