



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2015-020	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	December 22, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 24-inch water main along Reagan Drive, the existing 24-inch and 48-inch water mains along North Tryon Street and the existing 2-inch water main that runs from Reagan Drive to parcels under review along existing Driveway.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains on Reagan Drive at the northeast corner of parcels under review, as well as the existing 8-inch gravity sewer main along the north bound lane of North Tryon Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.