



**Charlotte Mecklenburg Utility Department**  
5100 Brookshire Boulevard  
Charlotte, NC 28062  
Re-Zoning Petition Review

<b>Petition #:</b>	2015-021	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	December 22, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 16-inch water main along West Morehead Street.

Access to the CMUD Sewer Service is available from the existing 36-inch gravity sewer mains along West Morehead Street, the public ROW along 1-77, and through the parcel under review. Developer will need to work with Charlotte Water's Installation and Development Services if any development of property will affect existing sewer infrastructure.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.