



Petition #:	2015-027	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	January 21, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains along Cherry Street, East 1st Street, Luther Street, and South Torrence Street.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains along Cherry Street, East 1st Street, and Luther Street. There is also an existing 8-inch gravity sewer main within parcel under review. Developer should contact Charlotte Water's Installation & Development Services for information regarding development around this gravity main.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.