



<b>Petition #:</b>	2015-032	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	January 21, 2015
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability via the existing 2-inch and 8-inch water mains along Baxter Street.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains along Luther Street and Eli Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.