



Petition #:	2015-034	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	January 21, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 8-inch and 12-inch water mains along Colony Road and the existing 24-inch water main along Sharon Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main along Colony Road, and the existing 8-inch gravity sewer mains that along the parcels under review between Roxborough Road and Sharon Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.