



Petition #:	2015-040	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	February 26, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 8-inch and 2-inch water mains along Lamar Avenue and alongside parcel boundary.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains that runs through the south side of parcel under review, alongside East Independence Boulevard.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.