



Petition #:	2015-042	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	February 26, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 6-inch water main along Woodward Avenue and the existing 12-inch water main along Statesville Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch and 12-inch gravity sewer mains along Woodward Avenue and the existing 8-inch gravity sewer main along Statesville Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.