



<b>Petition #:</b>	2015-043	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	February 26, 2015
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability via the existing 8-inch water main along Carolina Lily Lane. This 8-inch water main comes to a stop on the opposite side of Mallard Creek Road, approximately 200 feet from the Northwest corner of parcel under review.

In relation to the parcels under review, Charlotte Water does not currently have sewer system availability at the parcels under review. The closest sewer availability is approximately 650 feet from the Northwest corner of parcel, along Carolina Lily Lane. Developer should contact Charlotte Water's Installation & Development Services for information regarding development around sewer services for these parcels.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.