



Petition #:	2015-044	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	February 26, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 16-inch water main along Providence Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via the two existing 8-inch sewer mains. The first is along Springs Farm Lane, and is approximately 200 feet from parcel under review. The second 8-inch gravity sewer main is located to the west of Providence Road, and north of Springs Farm Lane. The gravity is approximately approximately 100 feet from parcel under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.