



|                           |              |                       |                          |
|---------------------------|--------------|-----------------------|--------------------------|
| <b>Petition #:</b>        | 2015-046     | <b>Review Number:</b> | 1                        |
| <b>Petition Reviewer:</b> | Matt Bedford | <b>Date Reviewed:</b> | February 26, 2015        |
| <b>Phone Number:</b>      | 704-391-5163 | <b>Email Address:</b> | mbedford@charlottenc.gov |

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability via the existing 48-inch, 36-inch, and 8-inch water mains along Providence Road and the existing 30-inch and 12-inch water mains along Fairview Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via existing 8-inch gravity sewer main along Providence Road, and the existing 8-inch gravity sewer mains to the northern corner of parcel.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.