



Petition #:	2015-047	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	February 26, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 12-inch, 20-inch, 36-inch, and 60-inch water mains that run along North Tryon Street and North I-85 Service Road, as well as the existing 12-inch water main along Macfarlane Boulevard

In relation to the parcels under review, Charlotte Water has sewer system availability via existing 8-inch gravity sewer main along Macfarlane Boulevard

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.