



Petition #:	2015-051	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	March 23, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 8-inch water main along North Brevard Street and the existing 6-inch water mains along Jordan Place and Charles Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability via existing 8-inch gravity sewer mains along Charles Avenue and Jordan Place, as well as the existing 10-inch gravity sewer main along North Brevard Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.