

**Date:** 3/16/15  
**Petition:** 2015-052  
 NR Pinehurst Property Owner, LLC

**Staff Contact:** Brian Horton  
**Telephone:** 704-353-0018  
**Email:** bhorton@charlottenc.gov  
**Attachments:** Bus stop pad detail

**I. SUMMARY REMARKS:**

The proposed development standard note #10 should refer to Standard 60.01B (ten-foot pad), instead of 60.01A (five-foot pad). Below is an image of the standard detail (60.01B) for the upgraded bus stop on Providence Road. This single requested stop will replace two existing bus stops along the current site's frontage.

Please contact me if there are any questions related to this request. Thank you.

