



Petition #:	2015-052	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	March 23, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 48-inch and 8-inch water mains along Providence Road.

In relation to the parcel under review, Charlotte Water has sewer system availability via existing 8-inch gravity sewer that runs through parcel, as well as the 8-inch gravity sewer main on Providence Road and the 24-inch gravity sewer main along runs McMullen Creek, north of parcel.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.