



Petition #:	2015-054	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	March 23, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 12-inch water main along Moss Road and the existing 16-inch water main along South Tryon Street.

In relation to the parcels under review, Charlotte Water has sewer system availability via existing 8-inch gravity sewer along Moss Road and South Tryon Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.