



# CHARLOTTE FIRE DEPARTMENT

500 Dalton Av  
Charlotte, NC 28204  
Plan Review Sheet

<b>Project:</b>	September Packet	<b>Review Number:</b>	2015-097->2015-106
<b>Control Number:</b>	2 of 2	<b>Date Reviewed:</b>	28 July 2015
<b>Fire Plans Examiner:</b>	J Wright	<b>Email Address:</b>	jswright@charlottenc.gov
<b>Phone Number:</b>	704.432.1752	<b>Fax Number:</b>	704.336.5190

## Comments:

- 2015-097 OK AS SUBMITTED. Approx.. 1500 sq ft addition. No issues.
- 2015-098 No comment
- 2015-099 No comment
- 2015-100 No comment
- 2015-101 No comment
- 2015-102 No comment. Rezone from I-2 to TOD-M
- 2015-103 No comment
- 2015-104 No comment
- 2015-105 townhomes 2 stories 1500 gpm, 3 stories <2500 sq ft 1750 gpm and 3 stories >2500 sq ft is 2000 gpm.  
20' unobstructed width for the fire apparatus access road. 150' of dead end truck travel requires an approved turn a round.  
access within 150' of all exterior walls (non sprinkled) 200' (sprinkled)  
Provide current flow test from the closest hydrant serving the buildings.
- 2015-106 No comment

Comments by staff will be based on an initial review of conceptual and/or preliminary drawings and project information, and therefore are not to be considered as binding. Submittal of additional information, or a later more detailed evaluation of the plans, including an evaluation made by a field inspector after building permits have been issued, may result in a change in interpretation by the Department as to the application of the NC State Fire Code and Ordinances to the project.