



Petition #:	2015-107	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	August 21, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 6-inch water main located along Harris Woods Boulevard and 12-inch water mains along David Cox Road and Davis Lake Parkway.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located within the western section of the parcel and along Harris Woods Boulevard and Davis Lake Parkway.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.