



Petition #:	2015-110	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	August 26, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 24-inch water main located along Old Statesville Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main located along Old Statesville Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.