



To: Tammie Keplinger, CMPC
From: Ashley Botkin, Engineering Land Development
Date: August 19, 2015
Rezoning Petition #: 2015-110

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website:

<http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson – Please add the following note to the site plan: SUFFICIENT VEGETATIVE GROUND COVER SHALL BE MAINTAINED ON ALL "EARTH LOTS" TO PREVENT EROSION.

Please remove the following note from the site plan: STORM WATER DETENTION IS NOT REQUIRED. (FYI - Applicability of standard City ordinance requirements, including those for storm water management, will be determined upon application for site development permits, not during the rezoning process.

Gary Turner – No comments

Jay Wilson – No concerns