



Charlotte Storm Water  
600 East Fourth Street  
Charlotte, N C 28202-2844  
OFFC: 704 . 336 . RAIN  
FAX: 704 . 336 . 6586

## *Rezoning Petition Review*

---

**To:** Tammie Keplinger, CMPC

**From:** Doug Lozner

**Date of Review:** August 27, 2015 (***Revised November 2, 1016***)

**Rezoning Petition #:** 15-113

**Existing Zoning:** R-8

**Proposed Zoning:** B-2 (CD)

**Location of Property:** Approximately 0.93 acres located on the west side of S Tryon Street, between E Cama Street and E Peterson Drive.

**Recommendations Concerning Storm Water:** No additional recommendations are needed at this time.

***Recommendations  
Due to revisions:***

*Plan sheet RZ-1 indicates a portion of the proposed planting strip is located within a Storm Drainage Easement and over the existing drainage system. These combined uses are generally not compatible. The purpose of easements are to provide storm water conveyance. Buildings, required landscaping or any other objects which impede storm water flow, system performance or system maintenance are prohibited within the drainage easement limits.*