



<b>Petition #:</b>	2015-114	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	August 26, 2015
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along Remount Road and Greenland Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along Remount Road and Greenland Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.