



Petition #:	2015-115	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	August 26, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 6-inch water main along West 9th Street and the 4-inch water main along North Church Street.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 10-inch gravity sewer main along West 9th Street and the 8-inch gravity sewer main along North Church Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.