



<b>Petition #:</b>	2015-116	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	August 26, 2015
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability via the existing 16-inch water mains along Johnston Road and Providence Road West.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main that flows through the center of parcel 232-132-11.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.