



Petition #:	2015-118	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	August 26, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 12-inch water main along Nations Ford Road and the 8-inch water main along Tyvola Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main along Nations Ford.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.