



Petition #:	2015-120	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	October 5, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along Hedgemore Drive, Mockingbird Lane, and Park Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main located along Park Road at the southwest corner of Development Area C (as shown on Technical Data Sheet, page RZ-1). Existing 8-inch gravity sewer mains are also located along Hedgemore Drive and Abbey Place for Development Areas D & E (as shown on Technical Data Sheet, page RZ-1).

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.