



Petition #:	2015-126	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	October 6, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along North Brevard Street and North Caldwell Street and the 8-inch water main located along North Brevard Street and East 21st Street.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along North Brevard Street, North Caldwell Street, and East 21st Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.