



| | | | |
|---------------------------|--------------|-----------------------|------------------------------|
| Petition #: | 2015-127 | Review Number: | 1 |
| Petition Reviewer: | Brady Glover | Date Reviewed: | October 5, 2015 |
| Phone Number: | 704-391-5171 | Email Address: | brady.glover@charlottenc.gov |

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 6-inch water main located along Winnifred Street and the existing 8-inch water main located along West Bland Street.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along Winnifred Street and West Bland Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.