



Petition #:	2015-128	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	October 5, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch, 8-inch, and 12-inch water mains located along South Tryon Street, West Park Avenue, and Camden Road, respectively.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along Camden Road and South Tryon Street and the existing 10-inch gravity sewer main located along West Park Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.