



Petition #:	2015-129	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	October 5, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 6-inch water main located along Otts Street and the existing 8-inch water main located along Louise Avenue.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 10-inch gravity sewer main located along Louise Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.