



<b>Petition #:</b>	2015-132	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	October 6, 2015
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along Huntley Place.

In relation to the parcels under review, Charlotte Water does not currently have sewer system availability. The closest sewer system availability is approximately 60 feet east-southeast of parcel 155-103-39 on Huntley Place. The developer should contact Charlotte Water's Installation & Development Services for information regarding development around water services for these parcels.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.