



<b>Petition #:</b>	2016-003	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	November 13, 2015
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability via the existing 12-inch water main located along Nations Ford Road.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along Nations Ford Road and on the southern border of the property. An existing 10-inch gravity sewer main is also located along the eastern border of the property.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.