



Petition #:	2016-004	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	November 13, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 6-inch water main located along Park Road.

In relation to the parcel under review, the closest existing sewer mains are located along Park Road approximately 75 feet north of the northeast corner of the property and approximately 175 feet south of the southeast corner of the property. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to these sewer mains.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.