



| | | | |
|---------------------------|--------------|-----------------------|------------------------------|
| Petition #: | 2016-007 | Review Number: | 1 |
| Petition Reviewer: | Brady Glover | Date Reviewed: | November 13, 2015 |
| Phone Number: | 704-391-5171 | Email Address: | brady.glover@charlottenc.gov |

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 8-inch water main that extends along Central Avenue from Bellsouth Drive to North Sharon Amity Road. Additionally, an existing 8-inch water main is located along Wilora Lake Road.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8- and 10-inch gravity sewer mains located within the parcel extending from the northern border to the southern border. Additionally, existing 8-inch sewer mains are located along North Sharon Amity Road and Central Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.