



<b>Petition #:</b>	2016-008	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	November 20, 2015
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability via the existing 12-inch water main that extends along Brentmoor Drive, the existing 8-inch water main from Collins-Aikman Drive, and the existing 2-inch water main from Pike Road.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch sewer mains located along Brentmoor Drive and Pike Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.