



Petition #:	2016-009	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	November 23, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 12-inch water main located along Sandy Porter Road. It should be noted that water availability is only accessible to parcels 201-071-07, 201-07-08, and 201-071-10 through this water main.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch sewer mains located along Sandy Porter Road (east of parcels 201-071-07 and 201-07-08) and within the western portion of parcels 201-071-07 and 201-07-08.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.