



Petition #:	2016-010	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	November 23, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 6-inch water main located along Legranger Road.

In relation to the parcel under review, the closest existing sewer main is located approximately 120 feet north of the northern corner of the property. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to this sewer main.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.

